



# NOC Application Preview U.P Fire Service

**Acknowledgement No : 2024110405091105**

**Date : 19-04-2024**

NOC Id : UPFS/2020/19802/BLR/BULANDSHAHR/321/CFO

## Building Owner Detail

Owner Name : VINEET KUMAR

Mobile No. : 9897624376

E-Mail ID : bvpkickhurja@gmail.com

PAN No. :

Address : NAVALPURA VIKAS NAGAR, MANDIR WALI GALI, KHURJA, BULAND SHAHAR, 203131

## Building Detail

Type Of NOC Certificate : Renewal

Plot No./House No. : Khet No.895, Vill.- Khurja, Outside Chungi, Khurja Kalindi Kunj Khurja 203131

District : BULANDSHAHR

Fire Station : Khurja

Type Of Occupancy As Per NBC : Educational

Type Of Sub Occupancy As Per NBC : B1 School up to senior secondary level

Height Of Building (In Mtrs) : 7.80

Plot Area (In Sq. Mtrs) : 11720.00

Plot Covered Area (In Sq. Mtrs) : : 1816.01

Messrs : : BHARAT VIKAS PARISHAD KANYA UCHA MADHYAMIK VIDYALAYA

Number of Upper Basement : 0

Number of Lower Basement : 0

Number of Blocks / Towers : 6

Distance between blocks / Towers (mt.) : 18.00

Architect name : Mohd Zahid Ali

Architect Mobile no. : 9358020237

Architect Registration number : CE-ISE-LM-278

Architect address : Opp. Govt. Hospital Bulandshahr

## ब्लॉक / टावर आधारित विवरण

### ब्लॉक / टावर 1

तलों की कुल संख्या

अधिवासता के आधार पर भवनों के वर्गीकरण का समूह

1 से 1

Educational

ब्लॉक / टावर का नाम : A

पानी का भूमिगत टैंक की क्षमता (लीटर में) :

अधिवासता के आधार पर भवनों के निर्माण का प्रकार : टाईप-2

## भवन के चारो ओर खुले स्थान (मीटर में)

सामने (फ्रन्ट) : 6.00 मीटर

पीछे (रियर) : 6.00 मीटर

साईड-1 : 6.00 मीटर

साईड-2 : 6.00 मीटर

## पहुँच मार्ग (मीटर में)

पहुँच मार्ग की लम्बाई : 30.00 मीटर

पहुँच मार्ग की चौड़ाई : 9.00 मीटर

इलेक्ट्रिकल पम्प की संख्या एवं क्षमता (ली0/मिनटमें) प्रेशर के साथ :

डीजल पम्प की संख्या एवं क्षमता (ली0/मिनट में) :

जॉकी पम्प की संख्या एवं क्षमता (ली0/मिनट में) :

पानी का टेरिस टैंक की संख्या एवं क्षमता (लीटर में) :

टेरिस टैंक पम्प की संख्या एवं क्षमता (लीटर/मिनट में) :

स्प्रिंकलर इलैक्ट्रिक पम्प की क्षमता (लीटर/मिनट में) :